

## Aquarion Water Company PFAS Sampling Results

**Town/City:** Newtown / Bethel  
**Water System Name:** Newtown Regional

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Chimney Heights Well, POE	May 2019	4		5		ND		ND	
	Jun. 2021	4		4		3		ND	
	Aug. 2021	7		6		3		ND	
	Apr. 2022	7		7		3		ND	
	Sep. 2022	7	16	11	10	ND	49	ND	12
Newtown Wells, POE	May 2019	4		ND		ND		ND	
	Jun. 2021	4		6		2		ND	
	Aug. 2021	5		5		2		ND	
	Apr. 2022	4		3		ND		ND	
	Sep. 2022	5	16	6	10	3	49	ND	12

**Footnotes:**

\* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022. A yellow highlighted value denotes a concentration greater than this new level.

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.